

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/12/2011
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155693		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 , 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 01/10/2011	
NAME OF PROVIDER OR SUPPLIER SILVER OAKS HEALTH CAMPUS				STREET ADDRESS, CITY, STATE, ZIP CODE 2011 CHAPA DR COLUMBUS, IN 47203			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 11/18/10 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 01/10/11</p> <p>Facility Number: 002955 Provider Number: 155693 AIM Number: 200346570</p> <p>Surveyor: Phillip Komsiski, Life Safety Code Specialist</p> <p>At this PSR survey, Silver Oaks Health Campus was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire, and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies for the original building, Chapter 18, New Health Care Occupancies for the Transitional Care Suites, and 410 IAC 16.2 for both sections.</p> <p>Silver Oaks Health Campus is a one story sprinklered building consisting of two sections, the original building was constructed in 2001 and is of Type V (111) construction. In 2005, the Transitional Care Suites addition was constructed to the east of the original building and is also of Type V (111) construction. Because the original building was built in 2001, the 2000 edition of NFPA 101, LSC Chapter 19, Existing Health Care Occupancies was used to survey the original building. The Transitional Care Suites was built in 2005, and the 2000 edition of NFPA 101, LSC</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/12/2011
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155693		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 , 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 01/10/2011	
NAME OF PROVIDER OR SUPPLIER SILVER OAKS HEALTH CAMPUS				STREET ADDRESS, CITY, STATE, ZIP CODE 2011 CHAPA DR COLUMBUS, IN 47203			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>Continued From page 1</p> <p>Chapter 18, New Health Care Occupancies was used to survey the Transitional Care Suites addition.</p> <p>The building was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors and all residents sleeping rooms. The facility has a capacity of 119 and had a census of 84 at the time of this visit.</p> <p>Quality Review by Robert Booher, REHS, Life Safety Code Specialist-Medical Surveyor on 01/11/11.</p>			{K 000}			